

Borough of Point Pleasant

Application for Roadway Opening

(Supplemental)

The following conditions shall apply to the excavation, backfill, restoration and maintenance of trenches located beneath Municipal roadways within the Borough of Point Pleasant:

1. The limits of the proposed excavation(s) shall be line cut using suitable equipment intended for that purpose and shall be subject to the approval of the Borough.
2. All excavations shall be of sufficient width to permit all work to be done completely in the manner intended to prevent any undermining of adjacent paved surfaces.
3. Where on-site excavated soils are not deemed suitable as backfill, select fill as described by the appropriate NJDOT Standards shall be used for backfill.
4. After completion of subsurface work, fill material shall be spread in uniform horizontal layers not exceeding twelve inches (12") in thickness and shall be compacted in a manner consistent with the current NJDOT standards for Road and Bridge Construction.
5. Subbase for the restored excavation shall be a six inch (6") layer of compacted NJDOT Mix I-4 soil aggregate. After the subbase has been properly compacted, a minimum four inch (4") thick hot bituminous stabilized base course (NJDOT Mix I-2) shall be installed in two-two inch (2") lifts. The Municipal Engineer may allow the installation of the stabilized base in one-four inch (4") lift where conditions warrant. The stabilized base course shall then be coated with a grade RS-1 emulsified tack coat as specified by NJDOT. The hot bituminous surface course shall be FABC-1 and shall conform to the requirements of NJDOT Mix I-5. The compacted thickness of the surface course shall be a minimum of two inches (2") and shall be finished flush with the adjoining undisturbed pavement. Prior to the installation of the surface course the adjoining pavement edges shall be vertically cut to a smooth edge and thoroughly cleaned before receiving a coating of RS-1 tack coating. Where deemed necessary by the Municipal Engineer, the finished edge where the new and existing pavement match shall be infrared sealed.
6. In the event that conflicts with or damage to other utilities occurs, the applicant shall immediately provide notice to the proper authorities. The applicant shall be responsible for the cost of repairing and/or replacement of utilities damaged during their operations.
7. Traffic Controls shall be approved by the Borough's Public Safety Director at the Point Pleasant Police Department. Their phone number is 732 892-0060. This number should also be contacted in the event of any emergency.
8. All signs, barricades, cones, barrels, personnel, etc. used in the execution of work covered by this permit shall be in accordance with the current version of the Manual on Uniform Traffic Control Devices and shall be approved by the Borough's Police Department.
9. The applicant shall provide to the Borough the One-Call Damage Prevention System Confirmation Number prior to excavation.
10. The Borough must be contacted a minimum of 48 hours prior to the commencement of excavation. The contact phone number is 732 892-1287.
11. The applicant shall be responsible for periodically monitoring the condition of the restored trench and to make any repairs required to maintain same in good condition.